



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

Energy Storage Technology Advancement Partnership
(ESTAP) Webinar:


One Year In: Energy Storage Proves its Worth in Sterling, MA

March 7, 2018



CleanEnergy
States Alliance

Housekeeping



Use the red arrow to open and close your control panel

Join audio:

- Choose Mic & Speakers to use VoIP
- Choose Telephone and dial using the information provided

Submit questions and comments via the Questions panel

This webinar is being recorded. We will email you a webinar recording within 48 hours. CESA's webinars are archived at www.cesa.org/webinars

Celebrating 15 Years of State Leadership


Clean Energy States Alliance



Illinois Department of Commerce & Economic Opportunity



NYSERDA



Office of the People's Counsel
District of Columbia
Advocating, Protecting and Educating DC Consumers



Energy Storage Technology Advancement Partnership (ESTAP)

ESTAP is supported by the U.S. Department of Energy Office of Electricity and Sandia National Laboratories, and is managed by CESA.

ESTAP key activities:

- 1) Disseminate information to stakeholders through:
 - The ESTAP listserv (>4,000 members)
 - Webinars, conferences, information updates, surveys
- 2) Facilitate public/private partnerships at the state level to support energy storage demonstration project development.
- 3) Support state energy storage efforts with technical, policy and program assistance

Thank You:

Dr. Imre Gyuk

U.S. Department of Energy, Office of Electricity Delivery and Energy Reliability

Dan Borneo

Sandia National Laboratories




U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories



CleanEnergy
States Alliance



One Year In: Energy Storage Proves its Worth in Sterling, MA

- **Dr. Imre Gyuk**, U.S. Department of Energy - Office of Electricity Delivery and Energy Reliability
- **Ray Byrne**, Sandia National Laboratories
- **Sean Hamilton**, Sterling Municipal Light Department
- **Dan Borneo**, Sandia National Laboratories
- **Todd Olinsky-Paul**, Clean Energy States Alliance (Moderator)



Sterling, MA: Microgrid/Storage Project



Sterling, MA, October 2016



Sterling, MA, December 2016

Sterling Municipal Light Department.

\$1.5M Grant from MA Community Clean Energy Resiliency Initiative (Dept. of Energy Resources). DOE/Sandia. Clean Energy Group.


2MW/2hr storage with existing 3.4 MW PV to provide **resiliency** for Police HQ and Dispatch Center. Li-ion batteries provided by NEC.

Storage Economics in Action!

| Description (1MW/1hr) | \$ |
|--------------------------------|----------------|
| Arbitrage (buy low, sell high) | 13,321 |
| Reduced Monthly Peak | 98,707 |
| Reduced Yearly Peak | 115,572 |
| Frequency Regulation | 60,476 |
| Total | 288,076 |

Capital cost: \$1.7M/MW,
calc. potential benefits.
Simple payback: 6.7 years

R. Byrne, Sandia




2016 Dec. till 2017 Nov.
Actual Savings:

- Arbitrage \$11,731
- Monthly Peaks \$143,447
- Annual Peak \$240,660
- Total \$395,839

Energy Storage Procurement, Guidance Document for Municipalities Dan Borneo (Sandia)

Specific examples of the elements that should be included in a solicitation for the procurement and installation of a battery energy storage project designed to provide backup power during outages and facilitate timely cost recovery.



www.sandia.gov/ess
SAND 2016-8544

2017 GTM Grid Edge Award!

Visitors: Germany, Denmark, England, Japan, Malaysia, Taiwan

Massachusetts Follow-on Activities

- MA adopts 200 MWh utility energy storage procurement target
- ACES energy storage grants - \$20 Million
- Peak Demand Reduction Grant Program - \$4.68 Million

- Sterling Community Project: solar + storage
2 MWh energy storage with 1 MW community solar

- 7 more MA municipal utilities have resiliency grants with storage

- MMWEC, which serves 42 municipal utilities in MA, now dispatching Sterling. Proposes centralized operation and dispatch services

Exceptional service in the national interest



Sterling Municipal Light Department Analysis

Ray Byrne, Ph.D.

Acknowledgment: This research was funded by the Energy Storage program at the U.S. Department of Energy Office of Electricity Delivery and Energy Reliability, under the guidance of Dr. Imre Gyuk.



Sandia National Laboratories is a multimission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DENA0003525.

Outline

- Sterling Potential value streams:
 - Energy arbitrage
 - Reduction in monthly network load (based on monthly peak hour)
 - Reduction in capacity payments (based on annual peak hour)
 - Grid resilience
 - Frequency Regulation
- Results


Energy Arbitrage

- Buy low – sell high
- Several variants
 - Day ahead market – day ahead market
 - Day ahead market – real time market
 - Renewables – day ahead market


$$\frac{LMP_H}{LMP_L} \geq \frac{1}{\eta_c}$$

- Price variations must overcome efficiency losses, η_c

For example, $1/0.85 = 1.18$



Day ahead LMP, ISO-NE node 4476,
(LD.STERLING13.8), July 14, 2016



Day ahead LMP, ISO-NE node 4476,
(LD.STERLING13.8), March 23, 2017

Monthly Network Load Payments

- ISO-NE employs a regional network service (RNS) payment for use of the pool transmission facilities to move electricity into or within the New England balancing authority (BA) [1]

RNS payment based on the load coincident with the monthly regional peak load hour (monthly peaks)

$$\text{RNS} = (\text{Pool RNS Rate}) \times (\text{Monthly Network Load})$$

2 MW ~ \$208K/year benefit

| Year | Effective Date | Pool Transmission Facilities (PTF) Rate, \$/kW-year | Pool Transmission Facilities (PTF) Rate, \$/MW-month |
|------|----------------|---|--|
| 2007 | Feb 1 | 26.3076024 | \$2,192.30 |
| 2007 | Jun 1 | 27.9071165 | \$2,325.59 |
| 2008 | Mar 1 | 27.8897124 | \$2,324.14 |
| 2008 | Jun 1 | 43.7560841 | \$3,646.34 |
| 2008 | Dec 1 | 43.8466113 | \$3,653.88 |
| 2009 | Jun 1 | 59.9470029 | \$4,995.58 |
| 2010 | Jun 1 | 64.8268400 | \$5,402.24 |
| 2011 | Jun 1 | 63.8737400 | \$5,322.81 |
| 2011 | Oct 1 | 61.5059000 | \$5,125.49 |
| 2012 | Jun 1 | 72.7458500 | \$6,062.15 |
| 2013 | Jan 1 | 75.3400300 | \$6,278.34 |
| 2013 | Jun 1 | 85.2171500 | \$7,101.43 |
| 2014 | Jun 1 | 90.2789700 | \$7,523.25 |
| 2014 | Oct 1 | 88.7655200 | \$7,397.13 |
| 2014 | Nov 1 | 87.3466600 | \$7,278.89 |
| 2015 | Jun 1 | 98.7014700 | \$8,225.12 |
| 2016 | Jun 1 | 104.1004100 | \$8,675.03 |

[1] ISO-NE, “New England control area transmission services and ISO-NE open access transmission tariff: General business practices. section 2: Pool PTF rate, pool RNS rate and schedule 1 rate; and an overview of the RNS or T/Out service application process,” <http://www.iso-ne.com/>, 2016.

Forward Capacity Market Payments

- ISO-NE has implemented a Forward Capacity Market (FCM) because electricity markets alone do not provide adequate financial incentives to invest in new generation

$$\text{Capacity Payment} = (\text{Capacity Load Obligation}) \times (\text{Net Regional Clearing Price})$$

- Capacity load obligation determined on the annual peak day/hour identified by ISO-NE

SMLD CAPACITY CLEARING PRICE, ISO-NE. PERIOD RUNS FROM JUNE 1 TO MAY 31.

| Year | Price (\$/kW-Month) |
|-----------|---------------------|
| 2010-2011 | \$4.254 |
| 2011-2012 | \$3.119 |
| 2012-2013 | \$2.535 |
| 2013-2014 | \$2.516 |
| 2014-2015 | \$2.855 |

| Year | Price (\$/kW-Month) |
|-----------|---------------------|
| 2015-2016 | \$3.129 |
| 2016-2017 | \$3.150 |
| 2017-2018 | \$7.025 |
| 2018-2019 | \$9.551 |
| 2019-2020 | \$7.030 |

$$FCM_{savings} \approx (FCM \text{ obligation}) * LOAD_{reduction} / LOAD_{peak}$$

2016 data, 2 MW ~ $-(12 * 3.129 * 32968) * 2000 / 24039 = \$102,989$

Grid Resilience



- The benefit of “backup power” is equivalent to the “Value of Lost Load”
- Value of lost load (VOLL) – the average cost to customers per megawatt-hour of unserved load when they are disconnected during involuntary load shedding [1].
- VOLL typically calculated using:
 - Market prices (indirect method)
 - Surveys (direct method)
- Sterling application: backup power for first responders (police and dispatch center)
- Closest data point available in the literature: public administration (small commercial and industrial)
- Likely understates the value to Sterling



[1] Steven Stoft, Power System Economics: Designing Markets for Electricity, Wiley-IEEE Press, 2002.

Frequency Regulation

- Frequency regulation is an ancillary service to maintain grid frequency
- Different market implementations:
 - Regulation up/Regulation down, e.g., CAISO, ERCOT
 - Regulation (bidirectional), e.g., ISO-NE, PJM, MISO
- Automatic generation signal sent every 2-4 seconds
- FERC Order 755 – pay for performance: performance score and mileage payment
- Some ISOs have a “fast” AGC signal (e.g., PJM)



Arbitrage Results

Arbitrage optimization results using historical data

| year | 0.25 MW | 0.50 MW | 0.75 MW | 1.00 MW | 1.25 MW | 1.50 MW | 1.75 MW | 2.00 MW |
|-------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|
| 2010 | \$12,764 | \$23,175 | \$29,973 | \$33,927 | \$36,456 | \$38,234 | \$39,553 | \$40,781 |
| 2011 | \$11,226 | \$19,514 | \$25,129 | \$28,931 | \$31,545 | \$33,411 | \$34,861 | \$36,229 |
| 2012 | \$11,082 | \$19,340 | \$24,581 | \$27,920 | \$30,208 | \$31,934 | \$33,331 | \$34,653 |
| 2013 | \$18,211 | \$30,725 | \$39,285 | \$44,726 | \$48,619 | \$51,595 | \$54,005 | \$56,276 |
| 2014 | \$21,101 | \$35,596 | \$46,527 | \$53,851 | \$58,924 | \$62,748 | \$65,788 | \$68,657 |
| 2015 | \$14,261 | \$24,387 | \$31,328 | \$35,892 | \$39,019 | \$41,353 | \$43,201 | \$44,935 |

Results for a 4MWh system (Sterling is a 2MW, 3.9 MWh system)

Arbitrage + Regulation Results

Arbitrage + regulation optimization results using historical data

| year | 0.25 MW | 0.50 MW | 0.75 MW | 1.00 MW | 1.25 MW | 1.50 MW | 1.75 MW | 2.00 MW |
|-------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| 2010 | \$21,035 | \$40,330 | \$57,198 | \$72,545 | \$86,921 | \$100,764 | \$113,962 | \$127,145 |
| 2011 | \$20,117 | \$38,304 | \$55,137 | \$70,945 | \$85,923 | \$100,439 | \$114,363 | \$128,254 |
| 2012 | \$19,003 | \$36,275 | \$52,131 | \$66,934 | \$81,068 | \$94,795 | \$107,985 | \$121,140 |
| 2013 | \$33,543 | \$63,214 | \$90,902 | \$116,897 | \$141,655 | \$165,611 | \$188,550 | \$211,402 |
| 2014 | \$48,052 | \$92,768 | \$136,190 | \$178,293 | \$219,068 | \$259,011 | \$297,818 | \$336,578 |
| 2015 | \$54,209 | \$106,790 | \$158,784 | \$210,338 | \$261,461 | \$312,242 | \$362,471 | \$412,683 |

Results for a 4MWh system (Sterling is a 2MW, 3.9 MWh system)


Arbitrage + Regulation + RNS + FCM

Arbitrage + regulation + RNS + FCM optimization results using historical data

| year | 0.25 MW | 0.50 MW | 0.75 MW | 1.00 MW | 1.25 MW | 1.50 MW | 1.75 MW | 2.00 MW |
|------|----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2012 | \$45,129 | \$88,528 | \$130,501 | \$171,417 | \$211,653 | \$251,458 | \$290,688 | \$329,882 |
| 2013 | \$63,146 | \$122,418 | \$179,672 | \$235,229 | \$289,495 | \$342,908 | \$395,242 | \$447,486 |
| 2014 | \$79,724 | \$156,100 | \$231,170 | \$304,914 | \$377,324 | \$448,790 | \$518,937 | \$589,032 |
| 2015 | \$87,839 | \$174,029 | \$259,632 | \$344,788 | \$429,462 | \$513,712 | \$597,296 | \$680,849 |

Results for a 4MWh system (Sterling is a 2MW, 3.9 MWh system)


Optimization Results – Typical Week



2 MW, 4 MWh system

- Last week of July 2015
- Annual and monthly peaks
- Spend the majority of the time at 50% SOC performing frequency regulation
- Charge up to 100% SOC in hour prior to FCM peak
- Discharge for two consecutive hours (FCM and RNS peak)
- Return to 50% SOC and continue performing frequency regulation
- Note minimal arbitrage (qc, qd)
- Assumes an energy neutral (with losses) regulation signal

Optimization Results – Typical Day



Grid Resilience

- Grid Resilience - SMLD has identified 10kW as the critical load

| | Capacity | | | |
|------|----------|----------|-----------|-----------|
| | 1 MWh | 2 MWh | 3 MWh | 4 MWh |
| Days | 4.167 | 8.333 | 12.5 | 16.667 |
| VoLL | \$40,819 | \$81,629 | \$122,448 | \$163,267 |



- VoLL from [1], public administration (small commercial and industrial)
- Likely understates the value to Sterling because it involves first responders (police and fire)



[1] M. J. Sullivan, M. Mercuriov, and J. Schellenberg, "Estimated value of service reliability for electric utility customers in the United States," Ernest Orlando Lawrence Berkeley National Laboratory, Berkeley, CA, Tech. Rep. LBNL-2132E, June 2009.

Summary

- Arbitrage is more synergistic with other peak shaving applications
- Analysis shows significant potential revenue from:
 - FCM savings
 - RNS savings
 - Frequency regulation

- For more information, please refer to:

R. H. Byrne, S. Hamilton, D. R. Borneo, T. Olinsky-Paul, and I. Gyuk, “The value proposition for energy storage at the Sterling Municipal Light Department,” proceedings of the 2017 IEEE Power and Energy Society General Meeting, Chicago, IL, July 16-20, 2017, pp. 1-5. DOI: 10.1109/PESGM.2017.8274631

- Available at www.sandia.gov/ess

http://www.sandia.gov/ess/docs/journals/SterlingMA_2017PES_SAND2017-1093.pdf

Sterling Municipal Light Dept.




Energy Storage Proves its Worth Sterling, MA

March 7, 2018


Sean Hamilton, General Manager




Seven Day Forecast



June's 3 Year Historical Peak Hour



6/13/2017




Alert Ratings Explained

| Rating | Definition | Advice |
|--------|--|--|
| 0 | Projected peak is below the threshold by greater than 1,000 MW. | Take no action. This will not be the peak day. |
| 1 | Projected peak is below the threshold by an amount between 500 and 1,000 MW. | Take no action. Barring a dramatic miss by ISO this will not be the peak day. |
| 2 | Projected peak is below the threshold by an amount less than 500 MW. | Be aware of the situation. Peak load is approaching threshold, but will most likely not be the peak. |
| 3 | Projected peak is above the threshold by an amount less than 500 MW. | Send alert. Today has a chance of being the peak day |
| 4 | Projected peak is above the threshold by an amount between 500 and 1,000 MW. | Send alert. There is a strong chance that today will be the peak day |
| 5 | Projected peak is above the threshold by an amount greater than 1,000 MW. | Send alert. There is an extremely high probability that today will be the peak day. |

June 13, 2017 – ISO-NE Peak Day

Single Day Viewer

(>) Tue Jun 13 2017 00:00:00 - Wed Jun 14 2017 00:00:00 (<=)




Began Construction 10-12-2016

Reduces RNS Peak on 12-16-2016

Single Day Viewer


(>) Fri Dec 16 2016 00:00:00 - Sat Dec 17 2016 00:00:00 (<=)



KW Total / System Total

System Demand

(>) Tue Sep 02 2014 00:00:00 - Wed Sep 03 2014 00:00:00 (<=)



September 2, 2014

Loss of Solar during Peak Period Thunderstorm

- Today System Total KW L
- 2011 Coincident Peak 1.975MW SHD [Fri Jul 22 2011] L
- Yesterday System Total KW [Mon Sep 01 2014] L
- August 2013 Peak [Wed Aug 28 2013] L
- System Peak KW [Wed Aug 02 2006] L
- Threshold L

Costs To Install*

| | |
|-----------------------------|--------------------|
| >Engineering | \$116,212.03 |
| >Feasibility Study | \$7,000.00 |
| >BESS (with Inverter) | \$2,034,075.00 |
| >Other Equipment | \$154,129.61 |
| >Labor Incl- Line Crew | \$76,390.25 |
| >Legal | \$62,725.06 |
| >Testing/Commissioning | \$11,293.95 |
| >Admin, Ops Supv ,GM, Acct. | <u>\$80,893.14</u> |
| | \$2,542,719.04 |

* Does not include Optional Substation Communication or Relay Panel upgrades

Value of Battery Energy Storage

- **Grid Resiliency - Police and Dispatch Center**
- **Smoothing Intermittent Resources**
- **Regional Network Service (RNS) -Monthly Peak**
 - Captured 10/13 monthly peaks for a value of \$162,107k
- **Capacity Load Obligation Payments – Annual Peak**
 - Captured Annual Peak (June 13) for a value of \$244,460
- Energy Arbitrage-Value to Date \$13k, 36 Round Trip Operations
- **Frequency Regulation-Not Participating in this Market**

Source: The Value Proposition for Energy Storage for Sterling Municipal Light Department

Author Dr. Raymond Byrne, Sandia National Laboratories. www.energysterling.com

| Hour | HUB | WCMA | NEMA | SEMA | CT | RI | NH | VT | ME |
|-------------------|---------------|---------------|-----------------|--------|--------|--------|--------|--------|--------------------|
| 1 | 21.69 | 21.71 | 21.77 | 21.8 | 21.73 | 21.66 | 17.59 | 20.72 | 20.22 |
| 2 | 27.99 | 28.05 | 28.07 | 28.09 | 28.13 | 28.03 | 23.68 | 26.9 | 18.56 |
| 3 | 19.58 | 19.64 | 19.62 | 19.64 | 19.7 | 19.61 | 15.61 | 18.97 | 8.79 |
| 4 | -20.34 | -20.42 | -20.34 | -20.41 | -20.56 | -20.4 | -22.66 | -19.88 | -24.92 |
| 5 | -1.47 | -1.47 | -1.45 | -1.47 | -1.49 | -1.47 | -4.69 | -1.41 | -1.72 |
| 6 | -27.02 | -27.11 | -26.99 | -27.1 | -27.29 | -27.07 | -29.29 | -26.43 | -25.34 |
| 7 | -12.31 | -12.35 | -12.3 | -12.35 | -12.45 | -12.33 | -15.36 | -12.09 | -11.64 |
| 8 | 24.56 | 24.63 | 24.63 | 24.56 | 24.73 | 24.38 | 20.21 | 23.93 | 23.43 |
| 9 | 29.65 | 29.72 | 29.78 | 29.6 | 29.76 | 29.31 | 25.32 | 28.52 | 28.08 |
| 10 | 44.57 | 45.69 | 92.48 | 44.55 | 44.8 | 43.77 | 41.17 | 42.35 | 41.5 |
| 11 | 55.62 | 56.37 | 85.02 | 55.49 | 56.08 | 54.73 | 53.17 | 52.45 | 51.73 |
| 12 | 50.48 | 51.66 | 100.33 | 50.29 | 51.08 | 49.65 | 45.22 | 47.19 | 46.36 |
| 13 | 51.72 | 52.72 | 101.46 | 51.79 | 51.93 | 50.98 | 41.36 | 46.41 | 41.24 |
| 14 | 61.28 | 61.89 | 101.88 | 61.73 | 60.75 | 60.72 | 43.48 | 51.33 | 40.87 |
| 15 | 179.66 | 175.9 | 201.92 | 186.82 | 166.37 | 181.76 | 26.15 | 87.78 | -11.88 |
| 16 | 278.24 | 274.75 | 299.81 | 285.15 | 266 | 278.96 | 132.98 | 187.31 | 88.79 |
| 17 | 285.91 | 282.35 | 330.31 | 293.65 | 271.68 | 286.84 | 124.29 | 185.3 | 79.3 |
| 18 | 389.17 | 387.24 | 674.03 | 401.56 | 363.88 | 390.88 | 122.59 | 222.72 | 49.49 |
| 19 | 219.73 | 217.88 | 342.98 | 226.43 | 205.44 | 220.51 | 77.09 | 129.77 | 26.21 |
| 20 | 159.24 | 156.44 | 173.21 | 164.06 | 149.17 | 159.87 | 62.95 | 99.91 | 37.33 |
| 21 | 141.67 | 139.13 | 172.38 | 146.17 | 132.1 | 142.37 | 48.44 | 84.47 | 23.3 |
| 22 | 78.47 | 77.66 | 124.87 | 80.75 | 73.68 | 78.67 | 28.82 | 48.64 | 7.15 |
| 23 | 29 | 28.49 | 40.16 | 30.14 | 26.84 | 29.32 | 3.55 | 14.79 | -7.99 |
| 24 | 25.52 | 25.36 | 26.46 | 25.93 | 24.94 | 25.56 | 15.74 | 20.89 | 15.83 |
| AVG | 88.03 | 87.33 | 122.09 | 90.29 | 83.63 | 88.18 | 37.39 | 57.52 | 23.53 |
| On Peak AVG | 129.94 | 128.91 | 180.95 | 133.3 | 123.39 | 130.17 | 56.05 | 84.55 | 35.31 |
| Off Peak AVG | 4.21 | 4.18 | 4.36 | 4.27 | 4.09 | 4.2 | 0.08 | 3.46 | -0.03 |
| Charged | .333/hr | | | | | | | | \$10.41 |
| Discharged | 1.2/hr | | | | | | | | \$1,096.36 |
| Net | | | | | | | | | \$ 1,085.95 |
| RNS Savings | Annual | Monthly | KW @ peak value | | | | | | |
| | 103.86 | 8.667 | 1200 | 10400 | | | | | \$10,400.40 |
| Savings | | | | | | | | | \$11,486.35 |

Arbitrage May 18, 2017

Resiliency Benefits

2 MW / 3.9 MWh Battery Energy Storage System

- BESS provides power up to 12 days
- BESS located in main substation
- Substation 2,300' from critical facility
- Separate circuit for BESS and CF
- MicroGrid capable with solar
- Live test performed April 27, 2017



UTILITY ENERGY STORAGE RANKINGS

TOP 10 ANNUAL WATTS-PER-CUSTOMER

| | | |
|----|---|------------------------|
| 1 | Sterling Municipal Light Department  | 533 Watts-per-customer |
| 2 | Glasgow EPB | 248 W/C |
| 3 | Imperial Irrigation District | 198 W/C |
| 4 | American Samoa Power Authority | 109 W/C |
| 5 | Indianapolis Power & Light Company | 42 W/C |
| 6 | Duke Energy Ohio | 23 W/C |
| 7 | Maui Electric | 17 W/C |
| 8 | San Diego Gas & Electric | 12 W/C |
| 9 | Green Mountain Power | 8 W/C |
| 10 | Commonwealth Edison, an Exelon Company | 6 W/C |

SEPA Solar Watts Per Customer Comparison

SEPA 2013

SEPA 2015

| Rank | Utility | W/C | | |
|------|---|-----|-------------------------|---|
| | | | Village of Minster (OH) | 2,104 |
| 1 | Sterling Municipal Light Dept (MA). | 831 | 2 | City of Palo Alto Utilities (CA) 1,846 |
| 2 | San Diego Gas & Electric Company (CA) | 461 | 3 | Roseville Electric Utility (CA) 1,416 |
| 3 | Silicon Valley Power/City of Santa Clara (CA) | 427 | 4 | Carey Municipal Electric Utility (OH) 1,351 |
| 4 | Arizona Public Service (AZ) | 368 | 5 | Vineland Municipal Electric Utility (NJ) 1,318 |
| 5 | Hawaiian Electric Company, Inc. (HI) | 329 | 6 | Ashburnham Municipal Light Plant (MA) 1,079 |
| 6 | Pacific Gas and Electric Company (CA) | 281 | 7 | Sterling Municipal Light Department (MA) 848 |
| 7 | Hawaii Electric Light Company (HI) | 182 | 8 | Imperial Irrigation District (CA) 750 |
| 8 | Maui Electric Company Ltd (HI) | 178 | 9 | Guam Power Authority (GU) 710 |
| 9 | Kauai Island Utility Cooperative (HI) | 167 | 10 | Silicon Valley Power (CA) 613 |
| 10 | Imperial Irrigation District (CA) | 159 | | |

Sterling Municipal Light Department

New Project

1 MW Community Solar with 1 MW / 2 MWh Battery Storage


- Battery charging achieved with solar
- Shift low cost solar to peak periods
- Allows residents access to solar, otherwise unavailable
- Peak shaving benefits shared with all ratepayers
- Program subscription roll out expected April 2018

Sort By: Trends

Refresh Current Historical Time Period: 1 Day Start Date: Mar 10, 2017 Number of Events: 30

- Trends
- Hourly Demand
- Hourly system demand
- Load Observation
- Single Day Viewer
- System Demand

Graph Tabular Summary



- Today System Total KW L
- 2011 Coincident Peak 1.975MW SHD [Fri Jul 22 2011] L
- Yesterday System Total KW [Thu Mar 09 2017] L
- March 2016 Peak Day [Wed Mar 02 2016] L
- System Peak KW [Wed Aug 02 2006] L
- Threshold L

Special Thanks To :

- SMLD Commissioners/Operations - For their support of this project
- Town of Sterling - For their continued support
- Judith Judson – MA DOER Commissioner
- Dr. Imre Gyuk - U.S. Dept of Energy, Energy Storage Program Director
- Sandia National Laboratories - Daniel Borneo PE., Dr. Raymond Byrne
- Todd Olinsky-Paul – Project Director of CEG and CESA
- MMWEC - Market Observation, Peak Forecasting and Operations
- Scott Reynolds, OPM and Mike Barrett, PLM, Design Engineering
- Jared Carpenter, Jim Frawley-Grant Technical Information

Contact Info

CESA Project Director:

Todd Olinsky-Paul

(Todd@cleanegroup.org)

Sandia Project Director:

Dan Borneo

(drborne@sandia.gov)

Webinar Archive:

www.cesa.org/webinars

ESTAP Website: bit.ly/CESA-ESTAP

ESTAP Listserv:

bit.ly/EnergyStorageList



Upcoming Webinars



The Status of State Grid Modernization Efforts

Friday, March 9 , 1-2pm ET

Valuing Resilience: Exploring the Role of Solar+Storage in Grid Outages

Wednesday, March 14, 1-2pm ET

New Financing Options for Solar+Storage in Low-Income Communities

Thursday, March 29, 1-2pm ET

Issues before FERC and the Potential Implications for Renewables and Energy Storage

Thursday, April 26, 1-2pm ET

Read more and register at www.cesa.org/webinars