



Energy Storage Technology Advancement Partnership  
(ESTAP) Webinar:

# The Value Proposition for Energy Storage at the Sterling Municipal Light Department

April 27, 2017

Hosted by Todd Olinsky-Paul  
ESTAP Project Director  
Clean Energy States Alliance




U.S. DEPARTMENT OF  
**ENERGY**



Sandia  
National  
Laboratories

# Housekeeping



Use the red arrow to open and close your control panel

Join audio:

- Choose Mic & Speakers to use VoIP
- Choose Telephone and dial using the information provided

Submit questions and comments via the Questions panel

This webinar is being recorded. We will email you a webinar recording within 48 hours. CESA's webinars are archived at [www.cesa.org/webinars](http://www.cesa.org/webinars)

# Thank You:

**Dr. Imre Gyuk**

U.S. Department of Energy,  
Office of Electricity Delivery and  
Energy Reliability

**Dan Borneo**

Sandia National Laboratories



# ESTAP is a project of CESA

**Clean Energy States Alliance (CESA)** is a non-profit organization providing a forum for states to work together to implement effective clean energy policies & programs:

**State & Federal Energy Storage Technology Advancement Partnership (ESTAP)** is conducted under contract with Sandia National Laboratories, with funding from US DOE.


## ESTAP Key Activities:

### 1. Disseminate information to stakeholders

- ESTAP listserv >3,000 members
- Webinars, conferences, information updates, surveys.

### 2. Facilitate public/private partnerships to support joint federal/state energy storage demonstration project deployment

### 3. Support state energy storage efforts with technical, policy and program assistance



**ESTAP Project Locations**



# Energy Storage Technology Advancement Partnership

[More CESA Projects](#)

## Overview

[ESTAP Resource Library](#)[ESTAP Webinars](#)[ESTAP News](#)[ESTAP Listserv Signup](#)

# ESTAP

**Project Director:** Todd Olinsky-Paul

**Contact:** Todd Olinsky-Paul, [Todd@cleanegroup.org](mailto:Todd@cleanegroup.org)

[SIGN UP FOR THIS e-MAILING LIST](#)

The Energy Storage Technology Advancement Partnership (ESTAP) is a federal-state funding and information sharing project, managed by CESA, that aims to accelerate the deployment of electrical energy storage technologies in the U.S.

The project's objective is to accelerate the pace of deployment of energy storage technologies in the United States through the creation of technical assistance and co-funding partnerships between states and the U.S. Department of Energy.

ESTAP conducts two key activities:

1) Disseminate information to stakeholders through:

- The ESTAP listserv (>2,000 members)
- Webinars, conferences, information updates



## NEW RESOURCES

October 14, 2015  
[Resilience for Free: How Solar+Storage Could Protect Multifamily Affordable Housing from Power Outages at Little or No Net Cost](#)  
By Clean Energy Group

September 30, 2015  
[Webinar Slides: Energy Storage Market Updates, 9.30.15](#)

## UPCOMING EVENTS

December 16, 2015  
[ESTAP Webinar: State of the U.S. Energy Storage Industry,](#)

[More Events](#)

## LATEST NEWS

November 30, 2015  
[Massachusetts Takes the Lead on Resilient](#)

# Panelists

- **Imre Gyuk**, U.S. Department of Energy - Office of Electricity Delivery and Energy Reliability
- **Sean Hamilton**, Sterling Municipal Light Department
- **Raymond Byrne**, Sandia National Laboratories
- **Todd Olinsky-Paul**, Clean Energy States Alliance (Moderator)



Sterling Municipal  
Light Department



# Energy Storage

----

## Developing Value Propositions through Grid Scale Validation

---

IMRE GYUK, DIRECTOR,  
ENERGY STORAGE RESEARCH, DOE-OE

# Sterling, MA: Microgrid/Storage Project



Sterling, MA, October 2016



Sterling, MA, December 2016

## Sterling Municipal Light Department.

\$1.5M Grant from MA Community Clean Energy Resiliency Initiative (Dept. of Energy Resources). DOE/Sandia. Clean Energy Group.

2MW/2hr storage with existing 3.4 MW PV to provide **resiliency** for Police HQ and Dispatch Center. Li-ion batteries provided by NEC.





DOE-OE providing funds and technical support towards expansion to 2MW/3MWh

- Backup for police station / dispatch center (resilience)
- Cost savings for reducing transmission capacity (monthly peak)
- Revenues from capacity charges to ISO (yearly peak)
- Arbitrage and Frequency Regulation
- Integration of intermittent PV

# Making the Microgrid Pay for itself !!

## An approach developed with Green Mountain Power at the Rutland, VT Project

Description (1MW/1hr)	\$
Arbitrage (buy low, sell high)	13,321
Reduced Monthly Peak	98,707
Reduced Yearly Peak	115,572
Frequency Regulation	60,476
<b>Total</b>	<b>288,076</b>

Capital cost: \$1.7M/MW  
simple payback: 6.7 years

R. Byrne


- ✓ 2016 December
- ✓ 2017 February
- ✓ 2017 March
- ✓ 2017 April



S. Hamilton

# Energy Storage Procurement, Guidance Document for Municipalities Dan Borneo (Sandia)

Specific examples of the elements that should be included in a solicitation for the procurement and installation of a battery energy storage project designed to provide backup power during outages and facilitate timely cost recovery.



[www.sandia.gov/ess](http://www.sandia.gov/ess)  
SAND 2016-8544

*2017 GTM Grid Edge Award!*

## Other DOE-OE Storage Projects:

### Eugene, OR, Water & Energy Board

Resiliency Microgrid

500kW Storage + 125kW PV + Diesel gen sets  
at 2 aggregated sites

### Cordova, AK, Study with ACEP

Hydropower Smoothing

### Kona, HI, with NELHA and HELCO

Enabling more solar PV

100kW/500kWh of V/V Batteries

### Orca Island with OPALCO

WA Clean Energy Fund

500kW/4 hour V/V system for resilience

With new Technologies  
Cost will go down, Safety and  
Reliability will increase

With every successful Project  
the Value Propositions will  
continue to increase!

More jobs will be created!!

# Sterling Municipal Light Dept.



## The Value Proposition for Energy Storage

April 27, 2017

Sean Hamilton General Manager

# Value of Energy Storage

- **Grid Resiliency-Police and Dispatch Center**
- **Smoothing Intermittent Resources- 3.4 MW Solar**
- **Regional Network Service (RNS) -Monthly Peak**
- **Capacity Load Obligation Payments –Annual Peak**
- **Energy Arbitrage**
- **Frequency Regulation**

# SEPA Solar Watts Per Customer Comparision

## SEPA 2013

Rank	Utility	W/C
1	Sterling Municipal Light Dept (MA).	831
2	San Diego Gas & Electric Company (CA)	461
3	Silicon Valley Power/City of Santa Clara (CA)	427
4	Arizona Public Service (AZ)	368
5	Hawaiian Electric Company, Inc. (HI)	329
6	Pacific Gas and Electric Company (CA)	281
7	Hawaii Electric Light Company (HI)	182
8	Maui Electric Company Ltd (HI)	178
9	Kauai Island Utility Cooperative (HI)	167
10	Imperial Irrigation District (CA)	159

## SEPA 2015

	Village of Minster (OH)	2,104
2	City of Palo Alto Utilities (CA)	1,846
3	Roseville Electric Utility (CA)	1,416
4	Carey Municipal Electric Utility (OH)	1,351
5	Vineland Municipal Electric Utility (NJ)	1,318
6	Ashburnham Municipal Light Plant (MA)	1,079
7	Sterling Municipal Light Department (MA)	848
8	Imperial Irrigation District (CA)	750
9	Guam Power Authority (GU)	710
10	Silicon Valley Power (CA)	613




Sort By: Trends

- Trends
  - Hourly Demand
  - Hourly system demand
  - Load Observation
  - Single Day Viewer
  - System Demand**

Refresh  Current  Historical Time Period: 1 Day Start Date: Mar 10, 2017 Number of Events: 80


Graph Tabular Summary



- Today System Total kW L
- 2011 Coincident Peak 1.975MW SHD [Fri Jul 22 2011] L
- Yesterday System Total kW [Thu Mar 09 2017] L
- March 2016 Peak Day [Wed Mar 02 2016] L
- System Peak kW [Wed Aug 02 2006] L
- Threshold L

# System Demand

( > ) Tue Sep 02 2014 00:00:00 - Wed Sep 03 2014 00:00:00 ( <= )



September 2, 2014

- Today System Total KW L
- 2011 Coincident Peak 1.975MW SHD [Fri Jul 22 2011] L
- Yesterday System Total KW [Mon Sep 01 2014] L
- August 2013 Peak [Wed Aug 28 2013] L
- System Peak KW [Wed Aug 02 2006] L
- Threshold L

# Final Real-Time Locational Marginal Prices (\$/MWh) 9/2/2014

Hour	HUB	WCMA	NEMA	SEMA	CT	RI	NH	VT	ME
1	44.23	44.35	44.48	44.03	44.40	44.39	43.85	43.75	41.88
2	38.15	38.31	38.22	37.84	38.36	38.17	37.74	37.75	36.11
3	32.98	33.11	33.01	32.68	33.09	32.96	32.67	32.54	31.54
4	28.23	28.34	28.26	28.01	28.26	28.19	28.02	27.90	27.13
5	28.06	28.19	28.07	27.83	28.17	27.97	27.89	27.81	26.98
6	32.97	33.10	32.98	32.67	33.11	33.09	32.86	32.82	31.77
7	37.33	37.46	37.49	37.03	37.51	37.24	37.44	37.29	36.38
8	40.87	40.99	41.07	40.62	41.05	40.90	41.01	40.86	39.96
9	35.01	35.09	35.25	36.10	35.06	41.63	35.25	34.96	34.33
10	45.85	45.99	46.13	46.51	46.09	50.20	46.07	45.92	44.34
11	73.81	74.12	74.15	73.39	74.69	73.55	74.11	74.15	71.31
12	89.80	90.11	90.35	89.45	93.48	89.51	90.14	89.86	86.67
13	185.70	186.25	187.11	185.44	190.47	185.53	186.15	184.95	178.01
14	554.71	555.62	560.77	555.12	558.00	555.55	555.69	551.95	530.00
15	206.54	206.72	209.37	207.47	308.93	207.60	206.72	205.66	196.51
16	70.45	70.57	71.51	70.86	158.68	70.91	70.15	70.67	65.38
17	86.23	86.34	87.48	86.72	168.94	86.71	85.96	86.14	80.60
18	133.90	134.22	135.05	134.18	174.45	134.14	133.38	133.73	126.21
19	72.92	73.14	73.35	72.90	107.74	72.81	72.65	73.38	68.10
20	75.16	75.35	75.60	75.14	82.61	75.08	75.14	75.41	71.28
21	74.36	74.62	74.61	74.20	75.75	73.96	74.14	74.76	70.18
22	55.07	55.27	55.32	54.86	55.76	54.56	54.81	54.91	52.16
23	38.60	38.75	38.82	38.36	39.02	38.21	38.48	38.42	36.99
24	54.55	54.76	54.98	54.15	55.00	54.01	54.41	54.12	52.48
AVG	88.98	89.20	89.73	88.98	104.53	89.45	88.95	88.74	84.85
On Peak AVG	114.94	115.20	116.00	115.08	138.17	115.68	114.99	114.73	109.50
Off Peak AVG	37.06	37.20	37.19	36.78	37.24	37.00	36.86	36.75	35.53








# Began Construction October 12, 2016

## Operating and Captures Peak on 12-16-2016

Single Day Viewer

( > ) Fri Dec 16 2016 00:00:00 - Sat Dec 17 2016 00:00:00 ( <= )



KW Total / System Total



Police & Dispatch Facility

Chocksett Substation

Wiles Rd 2 MW solar array

# Micro Grid Capable

© 2014 Google

Google


Imagery Date: 9/20/2010 42°27'00.86" N 71°44'14.78" W elev 434 ft





## UTILITY ENERGY STORAGE RANKINGS

### TOP 10 ANNUAL WATTS-PER-CUSTOMER

1	Sterling Municipal Light Department 	533 Watts-per-customer
2	Glasgow EPB	248 W/C
3	Imperial Irrigation District	198 W/C
4	American Samoa Power Authority	109 W/C
5	Indianapolis Power & Light Company	42 W/C
6	Duke Energy Ohio	23 W/C
7	Maui Electric	17 W/C
8	San Diego Gas & Electric	12 W/C
9	Green Mountain Power	8 W/C
10	Commonwealth Edison, an Exelon Company	6 W/C

# Special Thanks to :

- SMLD Commissioners/Operations - For their support of this project.
- Town of Sterling - For their continued support .
- Judith Judson – MA DOER Commissioner.
- Dr. Imre Gyuk - U.S. Dept of Energy, Energy Storage Program Director.
- Sandia National Laboratories - Daniel Borneo PE., Dr. Raymond Byrne.
- Todd Olinsky-Paul - Director of CEG and CESA.
- The Barr Foundation.
- MMWEC - Market Analysis.
- Scott Reynolds, Reynolds Engineering LLC, Owners Project Manager.
- Mike Barrett, PLM, Design Engineering
- Jared Carpenter, Jim Frawley-Grant Technical Information.

*Exceptional service in the national interest*



# Sterling Municipal Light Department Analysis

Ray Byrne, Ph.D.

**Acknowledgment:** This research was funded by the U.S. Department of Energy Office of Electricity Energy Storage Program, under the guidance of Dr. Imre Gyuk.



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000. SAND2017-4480 PE

# Outline

- Sterling Potential value streams:
  - Energy arbitrage
  - Reduction in monthly network load (based on monthly peak hour)
  - Reduction in capacity payments (based on annual peak hour)
  - Grid resilience
  - Frequency Regulation
- Formulation of the revenue maximization problem
  - Sandia approach for evaluating potential revenue
  - Energy storage model
  - Historical data
  - Solvers
- Results


# Energy Arbitrage

- Buy low – sell high
- Several variants
  - Day ahead market – day ahead market
  - Day ahead market – real time market
  - Renewables – day ahead market


$$\frac{LMP_H}{LMP_L} \geq \frac{1}{\eta_c}$$

- Price variations must overcome efficiency losses,  $\eta_c$

For example,  $1/0.85 = 1.18$



Day ahead LMP, ISO-NE node 4476,  
(LD.STERLING13.8), July 14, 2016



Day ahead LMP, ISO-NE node 4476,  
(LD.STERLING13.8), March 23, 2017

# Monthly Network Load Payments

- ISO-NE employs a regional network service (RNS) payment for use of the pool transmission facilities to move electricity into or within the New England balancing authority (BA) [1]

RNS payment based on the load coincident with the monthly regional peak load hour (monthly peaks)

$$\text{RNS} = (\text{Pool RNS Rate}) \times (\text{Monthly Network Load})$$

2 MW ~ \$208K/year benefit

Year	Effective Date	Pool Transmission Facilities (PTF) Rate, \$/kW-year	Pool Transmission Facilities (PTF) Rate, \$/MW-month
2007	Feb 1	26.3076024	\$2,192.30
2007	Jun 1	27.9071165	\$2,325.59
2008	Mar 1	27.8897124	\$2,324.14
2008	Jun 1	43.7560841	\$3,646.34
2008	Dec 1	43.8466113	\$3,653.88
2009	Jun 1	59.9470029	\$4,995.58
2010	Jun 1	64.8268400	\$5,402.24
2011	Jun 1	63.8737400	\$5,322.81
2011	Oct 1	61.5059000	\$5,125.49
2012	Jun 1	72.7458500	\$6,062.15
2013	Jan 1	75.3400300	\$6,278.34
2013	Jun 1	85.2171500	\$7,101.43
2014	Jun 1	90.2789700	\$7,523.25
2014	Oct 1	88.7655200	\$7,397.13
2014	Nov 1	87.3466600	\$7,278.89
2015	Jun 1	98.7014700	\$8,225.12
2016	Jun 1	104.1004100	\$8,675.03

[1] ISO-NE, “New England control area transmission services and ISO-NE open access transmission tariff: General business practices. section 2: Pool PTF rate, pool RNS rate and schedule 1 rate; and an overview of the RNS or T/Out service application process,” <http://www.iso-ne.com/>, 2016.

# Forward Capacity Market Payments

- ISO-NE has implemented a Forward Capacity Market (FCM) because electricity markets alone do not provide adequate financial incentives to invest in new generation

$$\text{Capacity Payment} = (\text{Capacity Load Obligation}) \times (\text{Net Regional Clearing Price})$$

- Capacity load obligation determined on the annual peak day/hour identified by ISO-NE

SMLD CAPACITY CLEARING PRICE, ISO-NE. PERIOD RUNS FROM JUNE 1 TO MAY 31.

Year	Price (\$/kW-Month)
2010-2011	\$4.254
2011-2012	\$3.119
2012-2013	\$2.535
2013-2014	\$2.516
2014-2015	\$2.855

Year	Price (\$/kW-Month)
2015-2016	\$3.129
2016-2017	\$3.150
2017-2018	\$7.025
2018-2019	\$9.551
2019-2020	\$7.030

2016 data, 2 MW ~ \$2000\*12\*3.15 = \$75,600

# Grid Resilience

- The benefit of “backup power” is equivalent to the “Value of Lost Load”
- Value of lost load (VOLL) – the average cost to customers per megawatt-hour of unserved load when they are disconnected during involuntary load shedding [1].
- VOLL typically calculated using:
  - Market prices (indirect method)
  - Surveys (direct method)
- Sterling application: backup power for first responders (police and dispatch center)
- Closest data point available in the literature: public administration (small commercial and industrial)
- Likely understates the value to Sterling





[1] Steven Stoft, Power System Economics: Designing Markets for Electricity, Wiley-IEEE Press, 2002.




# Frequency Regulation

- Frequency regulation is an ancillary service to maintain grid frequency
- Different market implementations:
  - Regulation up/Regulation down, e.g., CAISO, ERCOT
  - Regulation (bidirectional), e.g., ISO-NE, PJM, MISO
- Automatic generation signal sent every 2-4 seconds
- FERC Order 755 – pay for performance: performance score and mileage payment
- Some ISOs have a “fast” AGC signal (e.g., PJM)



# Maximizing Revenue – Market Area



# Storage Model - Arbitrage

- Assume price insensitive to supply (if not -> production cost modeling)
- Typically use 1 hour data
- Energy storage model – arbitrage

$$S_t = \gamma_s S_{t-1} + \gamma_c q_t^R - q_t^D \quad \forall t \in T$$

$T$  number of time periods in optimization.

$S_t$  state-of-charge at the end of period  $t$  (MWh).

$q_t^D$  energy discharged in period  $t$  (MWh).

$q_t^R$  energy charged in period  $t$  (MWh).

$\gamma_s$  storage efficiency over one period (%).

$\gamma_c$  conversion efficiency (%).

# Storage Model - Arbitrage

- Constraints on:
  - Total capacity
  - Maximum hourly charge/discharge quantity

$$S_t = \gamma_s S_{t-1} + \gamma_c q_t^R - q_t^D \quad \forall t \in T$$

$$0 \leq S_t \leq \bar{S}, \quad \forall t \in T$$

$$0 \leq q_t^R \leq \bar{q}^R, \quad \forall t \in T$$

$$0 \leq q_t^D \leq \bar{q}^D, \quad \forall t \in T$$

# Storage Model – Arbitrage + Regulation

- Assume price insensitive to supply (if not -> production cost modeling)
- Typically use 1 hour data
- Energy storage model – arbitrage + regulation

$$S_t = \gamma_s S_{t-1} + \gamma_c q_t^R - q_t^D + \gamma_c \gamma_t^{RD} q_t^{REG} - \gamma_t^{RU} q_t^{REG}$$

$S_t$  state of charge at time  $t$ , ( $MWh$ )

$\gamma_s$  storage efficiency (losses over one time period)

$\gamma_c$  conversion efficiency

$q_t^R$  recharge quantity at time  $t$ , ( $MWh$ )

$q_t^D$  discharge quantity at time  $t$ , ( $MWh$ )

$\gamma_t^{RD}$  fraction of regulation down bid called at time  $t$

$\gamma_t^{RU}$  fraction of regulation up bid called at time  $t$

$q_t^{REG}$  accepted regulation quantity at time  $t$ , ( $MWh$ )

# Storage Model – Arbitrage + Regulation

- Constraints on:
  - Total capacity
  - Maximum hourly charge/discharge quantity


$$S_t = \gamma_s S_{t-1} + \gamma_c q_t^R - q_t^D + \gamma_c \gamma_t^{RD} q_t^{REG} - \gamma_t^{RU} q_t^{REG}$$

$$\begin{aligned} \rightarrow q_t^{REG} \leq S_t \leq \bar{S} - q_t^{REG}, \quad \forall t \in T \\ 0 \leq q_t^R + q_t^{REG} \leq \bar{q}^R, \quad \forall t \in T \\ 0 \leq q_t^D + q_t^{REG} \leq \bar{q}^D, \quad \forall t \in T \end{aligned}$$

Even though we assume “perfect knowledge”, we are conservative – the state-of-charge must be capable of handling any frequency regulation signal (full amount in either direction)

# Storage Model – Arbitrage + Regulation


- Modeling regulation – need to assume fraction that is assigned



Note: some ISO's provide regulation signal data (e.g., PJM) – can calculate exactly

$$S_t = \gamma_s S_{t-1} + \gamma_c q_t^R - q_t^D + \gamma_c \gamma_{rd} q_t^{RD} - \gamma_{ru} q_t^{RU}$$

Account for fraction called



# Storage Model – Arbitrage + Regulation

## + RNS + FCM

- Same model as for arbitrage + regulation
- RNS + FCM +LMP are handled in the cost function
- It is possible to get the benefit of all three using the same “discharge”



# Energy Storage Model

- Arbitrage cost function

$$\max \sum_{t=1}^T [(P_t^D - C_t^D)q_t^D - (P_t^R + C_t^R)q_t^R] e^{-rt}$$

$$P_t^D, P_t^R = LMP_t$$

- Arbitrage + frequency regulation cost function\*

$$\max \sum_{t=1}^T [(P_t^D - C_t^D)q_t^D - (P_t^R + C_t^R)q_t^R + q_t^{REG} P_t^{REG}] e^{-rt}$$

$$P_t^D, P_t^R = LMP_t$$

- Arbitrage + frequency regulation\* + RNS + FCM cost function

$$\max \sum_{t=1}^T [(P_t^D - C_t^D)q_t^D - (P_t^R + C_t^R)q_t^R + q_t^{REG} P_t^{REG}] e^{-rt}$$

$$P_t^D, P_t^R = (LMP_t + FCM_t + RNS_t)$$

$P_t^D$	price for energy discharged, (\$/MWh)
$P_t^R$	price for energy recharged, (\$/MWh)
$C_t^D$	cost for energy discharged, (\$/MWh)
$C_t^R$	cost for energy recharged, (\$/MWh)
$P_t^{REG}$	price for regulation capacity, (\$/MWh)
$q_t^D$	quantity discharged at time $t$ , (MWh)
$q_t^R$	quantity recharged at time $t$ , (MWh)
$q_t^{REG}$	accepted regulation quantity at time $t$ , (MWh)
$e^{-rt}$	continuous discounting factor at time $t$

$C_t^D$  and  $C_t^R$  are assumed to be 0 for this analysis

\*NOTE: ISO-NE implemented a separate pay-for-performance mileage bid as of March 31, 2015. Since this analysis spans 2012-2016, we only included the capacity component for consistency.

# Historical Data

- Pull data from ISO-NE website using a MATLAB script and the restful services API:

<https://webservices.iso-ne.com/docs/v1.1/>

- Advantages:
  - get the data that you need and
  - save in a format that works for you

# Optimization Software

- Results were generated with Pyomo – a high level optimization framework developed by Sandia  
<http://www.pyomo.org/>
- Results were obtained with an open-source solver, GNU Linear Programming Kit (GLPK)
- Other options
  - MATLAB
  - Julia
  - Excel (need a 3<sup>rd</sup> party library)
  - Other high level optimization languages
  - Production cost modelling tool

# Arbitrage Results

Arbitrage optimization results using historical data

<b>year</b>	<b>0.25 MW</b>	<b>0.50 MW</b>	<b>0.75 MW</b>	<b>1.00 MW</b>	<b>1.25 MW</b>	<b>1.50 MW</b>	<b>1.75 MW</b>	<b>2.00 MW</b>
<b>2010</b>	\$12,764	\$23,175	\$29,973	\$33,927	\$36,456	\$38,234	\$39,553	\$40,781
<b>2011</b>	\$11,226	\$19,514	\$25,129	\$28,931	\$31,545	\$33,411	\$34,861	\$36,229
<b>2012</b>	\$11,082	\$19,340	\$24,581	\$27,920	\$30,208	\$31,934	\$33,331	\$34,653
<b>2013</b>	\$18,211	\$30,725	\$39,285	\$44,726	\$48,619	\$51,595	\$54,005	\$56,276
<b>2014</b>	\$21,101	\$35,596	\$46,527	\$53,851	\$58,924	\$62,748	\$65,788	\$68,657
<b>2015</b>	\$14,261	\$24,387	\$31,328	\$35,892	\$39,019	\$41,353	\$43,201	<b>\$44,935</b>

Results for a 4MWh system (Sterling is a 2MW, 3.9 MWh system)


# Arbitrage + Regulation Results

Arbitrage + regulation optimization results using historical data

<b>year</b>	<b>0.25 MW</b>	<b>0.50 MW</b>	<b>0.75 MW</b>	<b>1.00 MW</b>	<b>1.25 MW</b>	<b>1.50 MW</b>	<b>1.75 MW</b>	<b>2.00 MW</b>
<b>2010</b>	\$21,035	\$40,330	\$57,198	\$72,545	\$86,921	\$100,764	\$113,962	\$127,145
<b>2011</b>	\$20,117	\$38,304	\$55,137	\$70,945	\$85,923	\$100,439	\$114,363	\$128,254
<b>2012</b>	\$19,003	\$36,275	\$52,131	\$66,934	\$81,068	\$94,795	\$107,985	\$121,140
<b>2013</b>	\$33,543	\$63,214	\$90,902	\$116,897	\$141,655	\$165,611	\$188,550	\$211,402
<b>2014</b>	\$48,052	\$92,768	\$136,190	\$178,293	\$219,068	\$259,011	\$297,818	\$336,578
<b>2015</b>	\$54,209	\$106,790	\$158,784	\$210,338	\$261,461	\$312,242	\$362,471	\$412,683

Results for a 4MWh system (Sterling is a 2MW, 3.9 MWh system)

# Arbitrage + Regulation Results




# Arbitrage + Regulation + RNS + FCM

Arbitrage + regulation + RNS + FCM optimization results using historical data

year	0.25 MW	0.50 MW	0.75 MW	1.00 MW	1.25 MW	1.50 MW	1.75 MW	2.00 MW
2012	\$45,129	\$88,528	\$130,501	\$171,417	\$211,653	\$251,458	\$290,688	\$329,882
2013	\$63,146	\$122,418	\$179,672	\$235,229	\$289,495	\$342,908	\$395,242	\$447,486
2014	\$79,724	\$156,100	\$231,170	\$304,914	\$377,324	\$448,790	\$518,937	\$589,032
2015	\$87,839	\$174,029	\$259,632	\$344,788	\$429,462	\$513,712	\$597,296	\$680,849

Results for a 4MWh system (Sterling is a 2MW, 3.9 MWh system)

# Optimization Results – Typical Week




2 MW, 4 MWh system

- Last week of July 2015
- Annual and monthly peaks
- Spend the majority of the time at 50% SOC performing frequency regulation
- Charge up to 100% SOC in hour prior to FCM peak
- Discharge for two consecutive hours (FCM and RNS peak)
- Return to 50% SOC and continue performing frequency regulation
- Note minimal arbitrage (qc, qd)
- Assumes an energy neutral (with losses) regulation signal



# Optimization Results – Typical Day



# Grid Resilience

- Grid Resilience - SMLD has identified 10kW as the critical load

	Capacity			
	1 MWh	2 MWh	3 MWh	4 MWh
Days	4.167	8.333	12.5	16.667
VoLL	\$40,819	\$81,629	\$122,448	\$163,267



- VoLL from [1], public administration (small commercial and industrial)
- Likely understates the value to Sterling because it involves first responders (police and fire)




[1] M. J. Sullivan, M. Mercuriov, and J. Schellenberg, "Estimated value of service reliability for electric utility customers in the United States," Ernest Orlando Lawrence Berkeley National Laboratory, Berkeley, CA, Tech. Rep. LBNL-2132E, June 2009.

# Impact of Capacity

- Increased energy storage capacity increases the likelihood of hitting monthly/annual peaks

**Distribution of Sterling Monthly Peak Hours, Jan 2003 - Dec 2013**




Hour	Percent Occurrence
11	0.79 %
12	0.00 %
13	0.79 %
14	1.59 %
15	14.29 %
16	9.52 %
17	16.67 %
18	15.08 %
19	28.57 %
20	10.32 %
21	1.59 %
24	0.79 %

# Impact of Capacity

- Impact of capacity on hitting monthly peaks (based solely on historical data)

**Percentage of Monthly Peaks as a Function of Capacity  
Historical Data (2003-2013)**





# Impact of Capacity

- Distribution of annual peaks, 2000-2016

Hour	Percent
13	5.88 %
14	0 %
15	70.59 %
16	5.88 %
17	17.65 %


Distribution of ISO-NE Annual Peaks, 2000-2016



# Impact of Capacity

- Impact of capacity on hitting annual peaks (based solely on historical data)

**Percentage of Annual Peaks as a Function of Capacity  
Historical Data (2000-2016)**



# Future Work

- Investigating algorithms for predicting the monthly and annual peaks
- Plan to release Pyomo example code on the DOE energy storage website ([www.sandia.gov/ess](http://www.sandia.gov/ess)) towards the end of 2017

# Summary

- Arbitrage is more synergistic with other peak shaving applications
- Total potential revenue, 1MW, 1MWh system

Description	Total	Percent
Arbitrage	\$40,738	16.0%
RNS payment	\$98,707	38.7%
FCM obligation*	\$115,572	45.3%
Total	\$255,017	100%

- For a capital cost of ~1.7M, the simple payback is 6.67 years

\*2017-2018 data. Rates will likely be higher in the future, resulting in additional savings.



# Contact Info

CESA Project Director:

Todd Olinsky-Paul

([Todd@cleanegroup.org](mailto:Todd@cleanegroup.org))

Sandia Project Director:

Dan Borneo

([drborne@sandia.gov](mailto:drborne@sandia.gov))

Webinar Archive: [www.cesa.org/webinars](http://www.cesa.org/webinars)

ESTAP Website: [bit.ly/CESA-ESTAP](http://bit.ly/CESA-ESTAP)

ESTAP Listserv: [bit.ly/EnergyStorageList](http://bit.ly/EnergyStorageList)

