

State & Federal Energy Storage Technology Advancement Partnership (ESTAP)

Todd Olinsky-Paul
Clean Energy States Alliance



ESTAP is a project of CESA

Clean Energy States Alliance (CESA) is a non-profit organization providing a forum for states to work together to implement effective clean energy policies & programs:

- Information Exchange
- Partnership Development
- Joint Projects (National RPS Collaborative, Interstate Turbine Advisory Council)
- Clean Energy Program Design & Evaluations
- Analysis and Reports

CESA is supported by a coalition of states and public utilities representing the leading U.S. public clean energy programs.




ESTAP* Overview

Purpose: Create new DOE-state energy storage partnerships and advance energy storage, with technical assistance from Sandia National Laboratories

Focus: Distributed electrical energy storage technologies

Outcome: Near-term and ongoing project deployments across the U.S. with co-funding from states, project partners, and DOE

* (Energy Storage Technology Advancement Partnership)



ESTAP Key Activities

- Disseminate information to stakeholders
 - ESTAP listserv >500 members
 - Webinars, conferences, information updates, surveys
- Facilitate public/private partnerships at state level to support energy storage demonstration project development
 - Match bench-tested energy storage technologies with state hosts for demonstration project deployment
 - DOE/Sandia provide \$ for generic engineering, monitoring and assessment
 - Cost share \$ from states, utilities, foundations, other stakeholders



Thank You:

Dr. Imre Gyuk

U.S. Department of Energy,
Office of Electricity Delivery and
Energy Reliability

Dan Borneo

Sandia National Laboratories



Contact Information

Project website:

www.cleanenergystates.org/projects/energy-storage-technology-advancement-partnership/

Recording at www.cleanenergystates.org

CESA Project Director:

Todd Olinsky-Paul (Todd@cleanegroup.org)

Sandia Project Director:

Dan Borneo (drborne@sandia.gov)



Today's Speakers

James Ellison, Sandia National Laboratories

Dhruv Bhatnagar, Sandia National Laboratories

Dean Oshiro, Hawaiian Electric Company

Steven Rymsha, Maui Electric Company



Maui Electric Company Storage Evaluation Project: A Study for the DOE Energy Storage Systems Program

ESTAP Webinar

Jim Ellison, Dhruv Bhatnagar, and
Ben Karlson

March 6, 2013

SAND 2013-1840C



*Exceptional
service
in the
national
interest*



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

Project

- Previous studies have indicated that significant levels of wind curtailment on Maui likely
 - Installed wind capacity to increase from 30MW to 72MW by 2015
 - Daily minimum around 70MW
- We were asked to evaluate various energy storage options for Maui, to determine
 - How different storage system characteristics and system operating assumptions impact wind curtailment, and
 - To what degree can energy storage projects be cost-effective

Value of Storage to the Grid

- What is the value of storage to the grid?
 - One definition: the present value of the stream of benefits from a project, minus the capital and maintenance costs (NPV to the grid)
 - Where the stream of benefits are simply the savings (in annual costs of generation) that accrue from having the storage resource in a grid
- This is likely different from the value a resource owner can expect to obtain from a project (project NPV)
 - A merchant storage resource in a competitive market
 - Can only monetize those benefits that are included in the market
 - Must depend on the market to differentiate based on capabilities
- Focus here is on value to the grid

Valuing Electricity Storage

- Is difficult because the value depends on
 - The specific system the resource is planned for, including the
 - Load pattern and variability
 - Amount and variability of renewable generation
 - Characteristics of conventional units
 - The application the resource is used for
 - What it is compared with
 - The size of the resource
- How can a value be calculated?
 - If in a market, can use historical price information to approximate
 - If in a regulated system, need a different approach

What is a Production Cost Model?

- Answers the question: What is the least-cost dispatch to meet load?
- Consists of an interface, and an optimization solver
 - Interface – allows input of unit characteristics, load data, etc.
 - Solver – a commercial solver for solving large-scale optimization problems
- If we know the generator costs, why is this so complicated?
 - Optimizing for reserves as well as energy
 - Unit commitment decision
 - Economic dispatch
 - Operating reserves may be function of variable generation

Maui Grid Case Study



Source: Google Maps, March 5, 2013

- 210 MW maximum load
 - 70 MW minimum
- Renewable Capacity
 - 72 MW of wind planned
 - 10 MW of biomass
 - 15 MW distributed PV
- Conventional Capacity (diesel)
 - 30 MW of steam
 - 95 MW of reciprocating engines
 - 100 MW of combined-cycle


Study Scenarios

| Scenario Name | KPP Operations | Scenario Characteristics of interest |
|--------------------------------|---------------------|---|
| Reference run | | |
| 10MW / 15MWh battery | unchanged | spinning reserve value only |
| 10MW / 70MWh battery | unchanged | spin + arbitrage |
| 10MW / 70MWh battery, no K4 | K4 not available | spin + arbitrage + K4 off |
| 25MW Waena | K3/K4 not available | spin (w/minimum output) + K3/K4 off |
| 25MW / 175MWh battery | K3/K4 not available | spin + arbitrage + K3/K4 off |
| 25MW / 1200 MWh cryogen | K3/K4 not available | spin (w/min output) + large arbitrage + K3/K4 off |
| 30MW Waena + 5MW/35MWh battery | KPP not available | flexible diesel (spin) + 5MW spin + KPP off |
| 35MW Waena + trans. Line | KPP not available | flexible diesel (spin) + KPP off |

Reference Run

Annual Curtailment


16.5%



10-MW/15-MWh Battery Scenario

Annual Curtailment


14.0%



10-MW/70-MWh Battery Scenario

Annual Curtailment


9.5%




10-MW/70-MWh Battery, no K4

Annual Curtailment


7.1%



Wind Curtailment



Wind Dispatched by Scenario



Economic Characteristics

| Scenario (Note: all figures in millions of USD, unless otherwise noted) | Diesel | Wind | Diesel + Wind | Annual Savings | Estimated System Cost | Simple Payback (years) | NPV |
|--|--------|------|---------------|----------------|-----------------------|------------------------|------|
| Reference Run | 194.8 | 45.0 | 239.8 | - | - | - | - |
| 10MW/15MWh BESS | 190.0 | 46.3 | 236.3 | 3.5 | 11 | 3.1 | 34.4 |
| 10MW/70MWh BESS | 187.7 | 48.0 | 235.7 | 4.1 | 35 | 8.5 | 12.7 |
| 10MW/70MWh BESS, no K4 | 185.9 | 48.6 | 234.4 | 5.4 | 35 | 6.5 | 30.6 |
| 25MW Waena | 189.8 | 47.7 | 237.6 | 2.2 | 25 | 11.4 | 5.3 |
| 25MW/175MWh BESS | 180.2 | 49.4 | 229.7 | 10.1 | 87.5 | 8.7 | 29.6 |
| 25MW / 1200 MWh cryogen | 185.2 | 49.4 | 234.6 | 5.2 | 31.25 | 6.0 | 40.3 |
| 30MW Waena + 5MW/35MWh BESS | 185.5 | 48.6 | 234.1 | 5.7 | 47.5 | 8.3 | 31.0 |
| 35MW Waena + trans. Line | 188.9 | 47.7 | 236.7 | 3.1 | 40 | 12.9 | 2.7 |

Cost Savings Breakdown

| (Note: figures in millions of USD, unless otherwise noted) | Change in Diesel Gen (GWh) | Change in Wind Gen (GWh) | Marginal Diesel Gen cost | Marginal Wind Gen cost | Expected cost diff | Actual cost diff | % due to increased system efficiencies |
|--|----------------------------|--------------------------|--------------------------|------------------------|--------------------|------------------|--|
| Reference Run | - | - | - | - | - | - | - |
| 10MW/15MWh BESS | (7.7) | 7.6 | (1.7) | 1.4 | (0.31) | (3.5) | 91% |
| 10MW/70MWh BESS | (17.4) | 21.4 | (3.8) | 3.0 | (0.81) | (4.1) | 80% |
| 10MW/70MWh BESS, no K4 | (24.7) | 28.6 | (5.5) | 3.6 | (1.85) | (5.4) | 66% |
| 25MW Waena | (19.7) | 19.6 | (4.3) | 2.8 | (1.59) | (2.2) | 28% |
| 25MW/175MWh BESS | (33.5) | 43.3 | (7.4) | 4.5 | (2.96) | (10.1) | 71% |
| 25MW / 1200 MWh cryogen | (8.1) | 43.1 | (1.8) | 4.4 | 2.66 | (5.2) | 151% |
| 30MW Waena + 5MW/35MWh BESS | (27.4) | 29.4 | (6.1) | 3.7 | (2.40) | (5.7) | 58% |
| 35MW Waena + transmission line | (19.9) | 19.8 | (4.4) | 2.8 | (1.61) | (3.1) | 48% |

Conclusions

- All of the scenarios studied provided system savings compared to the reference case
- In the scenarios with additional storage alone, 2/3 or more of the system savings is from the more efficient operation of the conventional units
 - The efficient combined-cycle blocks, which typically provide spinning reserve, operate at higher levels with a storage system in place
 - Peaking units are not operated at minimum load to provide reserve
- Adding storage capacity to the 10MW battery helps to decrease wind curtailment
 - But does not increase the efficiency of conventional unit dispatch

Conclusions, contd.

- Storage provision of spinning reserve increases the efficiency of conventional unit use
 - Time-of-day shifting facilitates the dispatch of more wind
- Economics of time-of-day shifting depend on capturing large volumes
 - For two of the wind farms, PPAs specify volume discounts
- Waena biodiesel plants do not rank highly in terms of NPV
 - However, they allow the system to replace 150GWh/year of residual fuel-fired generation, at a net reduction in system operating cost
 - Even though they are required to burn biodiesel, which is about 3 times more expensive than residual fuel
- Significant upside to the Cryogen scenario if efficiencies can be increased above 50%

Future Tasks

- Is this study sufficient for MECO to make a decision on whether to install additional grid-level storage?
 - If not, what else is needed?

Contact Information

- Jim Ellison
 - E-mail: jelliso@sandia.gov
 - Telephone: (505) 286-7811
- Dhruv Bhatnagar
- Ben Karlson



**OFFICE OF
ELECTRICITY DELIVERY &
ENERGY RELIABILITY**

The study team gratefully acknowledges the support of Dr. Imre Gyuk and the Department of Energy's Office of Electricity Delivery & Energy Reliability.